




TOWN OF SUPERIOR

2016 *Water Quality Report*

SUPERIOR METROPOLITAN DISTRICT NO 1 2016 Consumer Confidence Report For Calendar Year 2015

CONSUMER CONFIDENCE REPORT

We are pleased to present to you this year's water quality report (for calendar year 2015). Our constant goal is to provide you with a safe and dependable supply of drinking water. Please contact [Jim Widner](mailto:Jim.Widner@superiorco.gov) at [303-499-3675](tel:303-499-3675) with any questions about the Drinking Water Consumer Confidence Report (CCR) or for public participation opportunities that may affect the water quality.



GENERAL INFORMATION

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or by visiting <http://water.epa.gov/drink/contaminants>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants:** viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants:** salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides:** may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- **Radioactive contaminants:** can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants:** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

LEAD IN DRINKING WATER

If present, elevated levels of lead can cause serious health problems (especially for pregnant women and young children). It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about lead in your water, you may wish to have your water tested. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

DETECTED CONTAMINANTS

SUPERIOR MD NO 1 routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2015 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination.

Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the next section of this report.

Note: Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section then no contaminants were detected in the last round of monitoring.

| Microorganism Contaminants Sampled in the Distribution System | | | | | | |
|---|-------------|---------|-------------|--|------|---------------|
| Name | Time Period | Results | Sample Size | MCL | MCLG | MCL Violation |
| Coliform (TCR) | March | 1 | 13 | More than 5% positive samples per period (If sample size is greater than or equal to 40) OR More than 1 positive sample per period (If sample size is less than 40) | 0 | No |
| Typical Sources: Naturally present in the environment | | | | | | |

| Lead and Copper Sampled in the Distribution System | | | | | | |
|--|--------------------------|-----------------|-------------|-----------------|--------------------|-------------------------------|
| Contaminant Name | Time Period | 90th Percentile | Sample Size | Unit of Measure | 90th Percentile AL | 90th Percentile AL Exceedance |
| Copper | 09/16/2015 to 09/25/2015 | 0.28 | 20 | ppm | 1.3 | No |
| Typical Sources: Corrosion of household plumbing systems; Erosion of natural deposits | | | | | | |
| Lead | 09/16/2015 to 09/25/2015 | 9 | 20 | ppb | 15 | No |
| Typical Sources: Corrosion of household plumbing systems; Erosion of natural deposits | | | | | | |

| Disinfection Byproducts Sampled in the Distribution System | | | | | | | | |
|--|------|---------|------------------|-------------|-----------------|-----|------|---------------|
| Name | Year | Average | Range Low - High | Sample Size | Unit of Measure | MCL | MCLG | MCL Violation |
| Total Haloacetic Acids (HAA5) | 2015 | 23.42 | 12.29 to 32.4 | 16 | ppb | 60 | N/A | No |
| Typical Sources: Byproduct of drinking water disinfection | | | | | | | | |
| Total Trihalomethanes (TTHM) | 2015 | 29.23 | 18.1 to 50.9 | 16 | ppb | 80 | N/A | No |
| Typical Sources: Byproduct of drinking water disinfection | | | | | | | | |

| Total Organic Carbon (Disinfection Byproducts Precursor) Removal Ratio of Raw and Finished Water | | | | | | | |
|--|------|---------|------------------|-------------|-----------------|-------------------|--------------|
| Name | Year | Average | Range Low - High | Sample Size | Unit of Measure | *TT Minimum Ratio | TT Violation |
| Total Organic Carbon Ratio | 2015 | 1.14 | 0.93 to 1.32 | 12 | Ratio | 1.00 | No |
| Typical Sources: Naturally present in the environment | | | | | | | |
| * If minimum ratio not met and no violation identified then the system achieved compliance using alternative criteria. | | | | | | | |

Summary of Turbidity Sampled at the Entry Point to the Distribution System

| Contaminant Name | Sample Date | Level Found | TT Requirement | TT Violation |
|-------------------------------------|-----------------------|--|---|--------------|
| Turbidity | Date/Month: August | <u>Highest single</u> measurement: 0.3 NTU | Maximum 1 NTU for any single measurement | No |
| Typical Sources: Soil Runoff | | | | |
| Turbidity | Month: December | <u>Lowest monthly</u> percentage of samples meeting TT requirement for our technology: 100 % | In any month, at least 95% of samples must be less than 0.3 NTU | No |
| Typical Sources: Soil Runoff | | | | |

Radionuclides Sampled at the Entry Point to the Distribution System

| Name | Year | Average | Range Low - High | Sample Size | Unit of Measure | MCL | MCLG | MCL Violation |
|---|------|---------|---------------------|-------------|-----------------|-----|------|---------------|
| Gross Alpha | 2011 | 1.4 | 1.4 to 1.4 | 1 | pCi/L | 15 | 0 | No |
| Typical Sources: Erosion of natural deposits | | | | | | | | |
| Combined Radium | 2011 | 0.2 | 0.2 to 0.2 | 1 | pCi/L | 5 | 0 | No |
| Typical Sources: Erosion of natural deposits | | | | | | | | |

Inorganic Contaminants Sampled at the Entry Point to the Distribution System

| Name | Year | Average | Range Low - High | Sample Size | Unit of Measure | MCL | MCLG | MCL Violation |
|---|------|---------|---------------------|-------------|-----------------|-----|------|---------------|
| Barium | 2015 | 0.03 | 0.03 to 0.03 | 1 | ppm | 2 | 2 | No |
| Typical Sources: Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits | | | | | | | | |
| Fluoride | 2015 | 0.15 | 0.15 to 0.15 | 1 | ppm | 4 | 4 | No |
| Typical Sources: Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories | | | | | | | | |

Secondary Contaminants**

**Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin, or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

| Name | Year | Average | Range Low - High | Sample Size | Unit of Measure | Secondary Standard |
|---|------|---------|---------------------|-------------|-----------------|--------------------|
| CARBON, DISSOLVED ORGANIC (DOC) | 2015 | 2.78 | 1.9 to 3.7 | 24 | N/A | |
| DICHLOROACETIC ACID | 2015 | 10.55 | 3.39 to 14.38 | 16 | N/A | |
| MONOCHLOROACETIC ACID | 2015 | 0.97 | 0 to 2.21 | 16 | N/A | |
| SUVA (SPECIFIC ULTRAVIOLET ABSORBANCE) | 2015 | 1.83 | 0.81 to 2.94 | 24 | N/A | |
| TRICHLOROACETIC ACID | 2015 | 11.9 | 8.31 to 17.1 | 16 | N/A | |
| UV ABSORBANCE @254 NM | 2015 | 5.65 | 1.6 to 10.5 | 24 | N/A | |

SOURCE WATER ASSESSMENT AND PROTECTION (SWAP)

The Colorado Department of Public Health and Environment has provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit <http://wqcdcompliance.com/ccr>. The report is located under "Source Water Assessment Reports", and then "Assessment Report by County". Select BOULDER County and find 107725; SUPERIOR MD NO 1 or by contacting JIM WIDNER at 303-499-3675. The Source Water Assessment Report provides a screening-level evaluation of potential contamination that **could** occur. It **does not** mean that the contamination **has or will** occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats.

This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Potential sources of contamination in our source water area are listed on the next page.

Please contact us to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Consumer Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.



Our Water Sources

SOURCE:
CARTER LAKE

SOURCE/WATER TYPE:
Intake/Surface Water

SOURCE:
MARSHALL LAKE
via Terminal Reservoir

SOURCE/WATER TYPE:
Intake/Surface Water

Potential sources of contamination in our source water area come from: EPA Superfund Sites, EPA Abandoned Contaminated Sites, EPA Chemical Inventory/Storage Sites, Permitted Wastewater Discharge Sites, Aboveground, Underground, and Leaking Storage Tanks, Solid Waste Sites, Existing/Abandoned Mine Sites, Other Facilities, Commercial/Industrial/Transportation, Low Intensity Residential, Urban Recreational Grasses, Row Crops, Fallow, Pasture/Hay, Deciduous Forest, Evergreen Forest, Septic Systems, Oil/Gas Wells, Road Miles

TERMS AND ABBREVIATIONS

Maximum Contaminant Level (MCL) – The highest level of a contaminant allowed in drinking water.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Violation (No Abbreviation) – Failure to meet a Colorado Primary Drinking Water Regulation.

Formal Enforcement Action (No Abbreviation) – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.

Variance and Exemptions (V/E) – Department permission not to meet a MCL or treatment technique under certain conditions.

Gross Alpha (No Abbreviation) – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.

Compliance Value (No Abbreviation) – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).

Average (x-bar) – Typical value.

Range (R) – Lowest value to the highest value.

Sample Size (n) – Number or count of values (i.e. number of water samples collected).

Parts per million = Milligrams per liter (ppm = mg/L) – One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion = Micrograms per liter (ppb = ug/L) – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Not Applicable (N/A) – Does not apply or not available.



124 E. COAL CREEK DR.
SUPERIOR, CO 80027

Presorted
Standard
U.S. Postage
PAID
Louisville, CO
Permit No. 58

**ECR WSS
Postal Customer
Superior, CO 80027**

Unregulated Contaminants***

EPA has implemented the Unregulated Contaminant Monitoring Rule (UCMR) to collect data for contaminants that are suspected to be present in drinking water and do not have health-based standards set under the Safe Drinking Water Act. EPA uses the results of UCMR monitoring to learn about the occurrence of unregulated contaminants in drinking water and to decide whether or not these contaminants will be regulated in the future. We performed monitoring and reported the analytical results of the monitoring to EPA in accordance with its Third Unregulated Contaminant Monitoring Rule (UCMR3). Once EPA reviews the submitted results, the results are made available in the EPA's National Contaminant Occurrence Database (NCOD) (<http://www.epa.gov/dwucmr/national-contaminant-occurrence-database-ncod>) Consumers can review UCMR results by accessing the NCOD. Contaminants that were detected during our UCMR3 sampling and the corresponding analytical results are provided below.


| Name | Year | Average | Range (Low - High) | Sample Size | Unit of Measure |
|----------------------------|------|---------|--------------------|-------------|-----------------|
| <u>Molybdenum</u> | 2013 | 0.48 | 0.46 - 0.50 | 4 | ppb |
| <u>Strontium</u> | 2013 | 48 | 46 - 50 | 4 | ppb |
| <u>Vanadium</u> | 2013 | 0.15 | 0.11 - 0.12 | 4 | ppb |
| <u>Hexavalent Chromium</u> | 2013 | 0.037 | 0.034 - 0.04 | 2 | ppb |

***More information about the contaminants that were included in UCMR3 monitoring can be found at: <http://www.drinktap.org/water-info/whats-in-my-water/unregulated-contaminant-monitoring-rule.aspx>. Learn more about the EPA UCMR at: <http://www.epa.gov/dwucmr/learn-about-unregulated-contaminant-monitoring-rule> or contact the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/contact.cfm>.

VIOLATIONS, SIGNIFICANT DEFICIENCIES, AND FORMAL ENFORCEMENT ACTIONS

No Violations of Formal Enforcement Actions

124 E. COAL CREEK DRIVE, SUPERIOR, CO 80027 303.499.3675



SUPERIORCOLORADO.GOV